

- 1 Stub out must be minimum 54" to the RIGHT of openings or ignition sources
- 2 Stub out must be minimum 20" to the LEFT of openings or ignition sources
- Stub out must be minimum 18" above FINISHED GRADE
- 4 Stub out must extend **through wall minimum 6**", consist of rigid pipe and be securely fastened





## OPENINGS & IGNITION SOURCES



WINDOW/DOOR OPENING



FOUNDATION VENT



TELEPHONE/ CABLE TV WIRING



DRYER VENT



POWER METER



ELECTRICAL OUTLET



DISCONNECT FOR HVAC



EXTERNAL TANKLESS WATER HEATER



ycnga.com

## CONTACTS

Fort Mill & Tega Cay: (803) 417-7393

Rock Hill & York: (803) 242-6370

Clover & Lake Wylie: (803) 417-0591

Business Development: (803) 323-5377

Construction: (803) 323-5321

EMERGENCY: 1-866-201-1001